

**WRITTEN QUESTION TO THE MINISTER FOR TRANSPORT AND TECHNICAL SERVICES BY  
DEPUTY G.C.L. BAUDAINS OF ST. CLEMENT**

**ANSWER TO BE TABLED ON TUESDAY 15th JULY 2008**

**Question**

Would the Minister advise of the capital cost and annual maintenance of fume extraction from the new bus station?

**Answer**

There are eight number extract fans fitted in the new bus station. The fans cost £60,000 to install and were fully funded by the developer as part of the base build of Liberation Station.

Annual running costs are difficult to predict as the fans are activated by air quality sensors which only operate when air quality falls below specified standards. However, manufacturer's estimates of annual running costs are £5,000 per year.